

Minutes of Pre-bid Meeting held on 21.06.2018 for the tender of "**Air conditioning of Proposed Office of Estate Div. at First Floor of Fairlie Ware House (Layout 1).**"

---

NIT No.: **KoPT/KDS/Mech/SE-I/ADV/491 dated 11.06.2018**  
E-Tender No. **KoPT/Kolkata Dock System/CME/11/18-19/ET/149**

**Present:**  
**Kolkata Port Trust Officials:**

1. Sri S. Sarkar - Executive Engineer (Elect)
2. Sri S. Joarder - Executive Engineer (Elect)

**Firm Representative**

1. Sri Ramesh Mandal - M/s Sky Decorations Pvt. Ltd.

The site was shown to the representative of the prospective bidder. Against query of the firm the following points were discussed and agreed upon:

1. BOQ SI. No. 8 & 10 in the NIT document – The installation of copper pipe between indoor & outdoor units and drain pipes from IDUs are to be laid above the false ceiling so that it remains concealed or depending upon the site condition, if pipes are required to be laid along the wall or below the false ceiling, suitable wooden/gypsum decorative cover over the pipes should be put to match the room décor and to hide the laying of pipes. The price for the decorative cover complete in all respect should be included here.

All other terms and conditions of the NIT remain unchanged. This minute is to be considered as a part of the NIT.

CHIEF MECHANICAL ENGINEER