

**KOLKATA PORT TRUST**  
**HALDIA DOCK COMPLEX**

**Tender No. SDM (P&E)/T/17/2018-19**  
**E-Tender No. KoPT/Haldia Dock Complex/P&E Div/19/18-19/ET/302 Dated Oct 12, 2018**

**ADDENDUM - I**

*CORRECTIONS / ADDITIONS / DELETIONS, ETC.*

**[Total Number of Page: 1]**

**NOTE :**

1. This "Addendum-I" should be read in conjunction with Bidding Document (including Notice Inviting e-Tender).
2. Consequential changes, arising out of this Addendum-I, will be deemed to have been effected, even if the same were not incorporated specifically in the Bidding Document.
3. All other terms and conditions of the Bidding Document (including Notice Inviting e-Tender) will remain unchanged.

**Addendum -I**

**Tender No. SDM (P&E)/T/17/2018-19**

**E-Tender No. KoPT/Haldia Dock Complex/P&E Div/19/18-19/ET/302 Dated Oct 12, 2018**

<b>Sl. No.</b>	<b>Page No.</b>	<b>Clause No.</b>	<b>As specified in the Bidding Document</b>	<b>To be deleted &amp; read as / Remarks</b>
1	68	2.6(Data sheet for High Mast)	Bottom section length(mm)x thickness(mm) : 10600x6	Bottom section length(mm)x thickness(mm) : 10600x8
2	62	6.1.6/ 5.4, (Section 6)	....The Lantern carriage shall be made of specially designed square steel tube having a three piece construction.....  Sl.No.5.4 of datasheet for High Mast: Number of Joint-3	Accepted manufacturer standard