Minutes of site inspection followed by Pre-bid Meeting held on 18.01.19 at 14-30 hours for the work "Supply, Delivery, Installation & Commissioning of LED Luminaries at Container Terminal, NS Dock and Coal Berth, KPD"

Enquiry letter No.: Mech/SE - II/25/186/153 dated 16.01.2019

Representative of (i) Expert Electricals, (ii) Modern Software Systems Pvt. Ltd., (iii) GD Power and Control Pvt. Ltd., (iv) Subhas Electric Works and (v) A. R. Rural Electricals attended for site inspection followed by Pre-bid meeting for the subject work. The site was inspected and details of queries made by the tenderers were clarified in respect of the scope of work as specified in BOQ. All terms and conditions of the Enquiry letter No. Mech/SE - II/25/186/ 153 dated 16.01.2019 shall remain unchanged except the following:

- (a) The cable shall be laid on a cushion of sand with brick protection on the top of the cable / GI Pipe with 16 (sixteen) nos. Bricks per metre instead of 8 (eight) nos. bricks per metre mentioned in BOQ Sl. No. 1(b) & 2(a).
- (b) Aluminium Conductor of 4C x 10 sq. mm. may be multi/ single stranded mentioned in BOQ Sl. No. 1.

This Minutes of the Pre-bid meeting shall become part of the tender and is required to be submitted duly signed along with the offer.

(S. Kansary) 18.01.19

Executive Engineer (Electrical)

Ar (8/8/19 (D. K. Kundu)

Asst. Ex. Engineer (Electrical)

EXPERT ELECTRICALS

Expert Electricals

Modern Software Systems Pvt. Ltd.

GD Power and Control Pvt. Ltd.

(Satish Singh) Subhas Electric Works

Saturd byl