





Minutes of site inspection followed by Pre-bid Meeting held on 23.04.15.2015 at 1100 hours for the tender for "Rewiring of Electrical Installation of Portland Park Quarters, Remount Road Quarters etc..".





NIT No. KoPT/KDS/Mech/SE-II/Adv/328 dt. 26.03.2015

PRESENT









A: Prospective Tenderers

Name of the tenderer	Name of the representative of the firm	Signature
Phinix	Shri Rajkumar Banerjee	
H S Enterprise	Shri T. Dey.	
B.B.Enterprises	Akshay Bhasin	
Subhash Electric work	Shamim Iqbal	

B: KOLKATA PORT TRUST

Name of the officer	Designation	Signature
Sri M. Ganguly	Project Engineer(Elect.)	
Sri K. B. Das	Executive Engineer (Elec-I)	
Sri Aditya Nandi	Executive Engineer (Elect-V)	
Sri S.K. Dhar	Executive Engineer (Elect) -KPD	

Representatives of above mentioned prospective tenderers attended the Site Inspection as well as the Pre-bid meeting. The site was inspected and details of queries made by the tenderers were clarified in respect of the scope of work as specified in BOQ. Against reply to query made on item No.25 of BOQ , it was clarified that... supplying sockets tapes for 80/0.3mm (6 sq. mm conductor) should be read as... sockets tapes for 56/0.3mm(4 sq. mm conductor)which was due to typographical error . All other terms and conditions of the NIT No. KoPT/KDS/Mech/SE-II/Adv/328 dt. 26.03.2015 shall remain unchanged. This minutes of the Pre-bid meeting shall become part of the NIT and is required to be submitted duly signed along with Techno-Commercial Bid(Par-I).

			
H.S.Enterprise	Phinix	B.B.Enterprises	Shamim Iqbal
			
Project Engineer	Ex. Engineer (Elect- I)	Ex. Engineer (Elect- V)	Ex. Engineer (Elect)-KPD