

ADDENDUM NOTICE

KOLKATA PORT TRUST
HALDIA DOCK COMPLEX

HDC Tender No. **SDM (P&E)/T/43/2019-2020** / E- Tender No. **KoPT/Haldia Dock Complex/P&E Div/6/19-20/ET/21**

Sub: **Tender for Providing Street light arrangement from Barge jetty gate No. 1 to VIP road crossing via Hoogly metcoke at Haldia Dock Complex, Kolkata Port Trust.**

Some changes in the Tender Document have been incorporated in Addendum. The complete Tender Document (including Tender Notice) and Addendum are available in the websites www.mstcecommerce.com ; <http://eprocure.gov.in> ; <http://kolkataporttrust.gov.in> and <http://haldiadock.gov.in>

KOLKATA PORT TRUST
HALDIA DOCK COMPLEX

Tender No. SDM (P&E)/T/43/2019-2020
E-Tender No. KoPT/Haldia Dock Complex/P&E Div/6/19-20/ET/21

**“Providing Street light arrangement from Barge jetty gate No. 1 to VIP road crossing via Hoogly metcoke at
Haldia Dock Complex, Kolkata Port Trust.”**

ADDENDUM - I

CORRECTIONS / ADDITIONS / DELETIONS, ETC.

[Total Number of Page: 2]

NOTE :

1. This “Addendum-I” should be read in conjunction with Bidding Document (including Notice Inviting e-Tender).
2. Consequential changes, arising out of this Addendum-I, will be deemed to have been effected, even if the same were not incorporated specifically in the Bidding Document.
3. All other terms and conditions of the Bidding Document (including Notice Inviting e-Tender) will remain unchanged.

Addendum -I

Tender No. SDM (P&E)/T/43/2019-2020

E-Tender No. KoPT/Haldia Dock Complex/P&E Div/6/19-20/ET/21

Sl. No.	Page No.	Clause No.	As specified in the Bidding Document	To be deleted & read as / Remarks
1	110	Bidding Form- VI Item No.4	<u>LT Cable:-</u> Supply of LT Cable, 1.1 KV grade, XLPE U.G. Alu. Cable as per Technical Specification. (i) Supply of 3.5 C X 50Sq.mm. - 13550Mtrs.	<u>LT Cable:-</u> Supply of LT Cable, 1.1 KV grade, XLPE U.G. Alu. Cable as per Technical Specification. (i) Supply of 3.5 C X 50Sq.mm. - 6500Mtrs. (ii) Supply of 4C X 25Sq.mm. - 7050Mtrs.
2	111-112	Bidding Form- VI Item No.10	Supply, laying and termination of size of 25 X 6 mm GI strip as per Technical Specification (i) Supply - 30Mtrs. (ii) Laying, termination, commissioning and interconnection between earthing station.- 30Mtrs.	Supply, laying and termination of size of 25 X 6 mm GI strip as per Technical Specification (i) Supply - 110Mtrs. (ii) Laying, termination, commissioning and interconnection between earthing station.- 110Mtrs.
3.	5	SOT	E-Tender No. KoPT/ Haldia Dock Complex/P&E Div/ 6 /18-19/ET/ 21	E-Tender No. KoPT/ Haldia Dock Complex/P&E Div/ 6 /19-20/ET/ 21
4.	6	SOT	Starting date & time of submission of e-Tender at http://www.mstcecommerce.com/eprochome/kopt: 14.06.2019 from 11:00 Hrs. (IST).	Starting date & time of submission of e-Tender at http://www.mstcecommerce.com/eprochome/kopt: 21.06.2019 from 11:00 Hrs. (IST).
5.	6	SOT	Closing date & time of submission of e-Tender at http://www.mstcecommerce.com/eprochome/kopt 24.06.2019 up to 15:00 Hrs. (IST).	Closing date & time of submission of e-Tender at http://www.mstcecommerce.com/eprochome/kopt 01.07.2019 up to 15:00 Hrs. (IST).
6.	6	SOT	Date & time of opening of Techno-commercial Bid & Price Bid 24.06.2019 up to 15:30 Hrs. (IST) onwards.	Date & time of opening of Techno-commercial Bid & Price Bid 01.07.2019 up to 15:30 Hrs. (IST) onwards.

Sl. No.	Page No.	Clause No.	As specified in the Bidding Document	To be deleted & read as / Remarks
7.	66	7.35 Sub- Clause 7.35.1	<p>Contractor is responsible to protect the work</p> <p>From the commencement of the works till issue of the "Certificate of Completion of Work", vide GCC Clause No. 9.65 hereof, the Contractor shall take full responsibility for the care thereof. Save for the excepted risks, any damage, loss or injury to the work, or any part thereof, shall be made good by the Contractor, at his own cost, as per instruction and to the satisfaction of the Engineer, failing which, the Engineer or his Representative may cause the same to be made good by any other agency and the expenses, incurred and certified by the Engineer, shall be recoverable from the Contractor, in whatever manner the Engineer shall deem proper. This clause will not apply to that part of the work, which might have been taken over by the Trustees on partial completion of the work and in such case, the Contractor's obligation will be limited to repairs and replacement for manufacturing or construction defects during the Defect Liability Period, as per the directions of the Engineer, as also for defects/damages, if any, caused to the work by the Contractor during such repairs and replacement during the Defect Liability Period.</p>	<p>Contractor is responsible to protect the work</p> <p>From the commencement of the works till issue of the "Certificate of completion after defect liability period and non-comprehensive maintenance contract period.", vide GCC Clause No. 7.65 hereof, the Contractor shall take full responsibility for the care thereof. Save for the excepted risks, any damage, loss or injury to the work, or any part thereof, shall be made good by the Contractor, at his own cost, as per instruction and to the satisfaction of the Engineer, failing which, the Engineer or his Representative may cause the same to be made good by any other agency and the expenses, incurred and certified by the Engineer, shall be recoverable from the Contractor, in whatever manner the Engineer shall deem proper.</p> <p>i) During Defect liability period (2years) contractor shall maintain for operation of complete system [excluding LED Luminaire for 5years] including safety ad security with minimum manning. If more than 2Years, port will make own arrangement for security.</p> <p>ii) HDC is planning to provide CISF for patrolling of the road including Lighting installation.</p>

HALDIA DOCK COMPLEX

KOLKATA PORT TRUST

QUERIES OF DIFFERENT FIRMS IN CONNECTION WITH THE PRE-BID MEETING HELD ON 12.06.2019

for

**“Providing Street light arrangement from Barge jetty gate No. 1 to VIP road crossing via Hoogly metcoke at
Haldia Dock Complex, Kolkata Port Trust.**

Tender No. SDM (P&E)/T/43/2019-2020

E-Tender No. KoPT/Haldia Dock Complex/P&E Div/6/19-20/ET/21

Sl. No.	Reference	Queries of the firms	HDC, KoPT's Clarifications
1.	Schedule of Tender, clause 3.5, page no. 6	We request you to accept EMD in the form of BG	Tender condition prevails.
2.	BIDDING FORM-VI, PRICE SCHEDULE , item 4, page no. 110	Quantity of 3.5 C x 50 Sq.mm cable can be reduced and for Pole to pole looping 4C x 16 or 4C x 25 cable sufficient , that should be included, kindly advise	Please see addendum.
3.	BIDDING FORM-VI, PRICE SCHEDULE , item 10, page no. 111	As per the scope of tender, quantity of GI strip is too low, it should be minimum 110 mtr. kindly advise	Please see addendum.
4.		Requisition of including brand LT (Lighting Technologies India Pvt. Ltd) in approved make list of LED Luminaries.	Tender condition prevails.
5.		Enlisting UTKARSH brand in HDC Pole make List/ Vendor List.	Tender condition prevails.
6.		Enlisting JK Poles make for Street Light Poles. We have supplied to IOCL, BPCL & HDC.	Tender condition prevails.
7.		May kindly clarify scope of security of installation during execution of the job and also during post commissioning i.e. comprehensive and non comprehensive maintenance period.	Please see addendum.