

**ADDENDUM NOTICE**

**KOLKATA PORT TRUST  
HALDIA DOCK COMPLEX**

HDC Tender No. **SDM (P&E)/T/48/2019-20/** E- Tender No. **KoPT/Haldia Dock Complex/P&E  
Div/10/19-20/ET/38**

Sub: **Tender for Supply, Installation, Testing and Commissioning of 33 kV Over Head Line & Under  
Ground Cable from Intake Substation to GC Berth Substation for strengthening of power supply  
arrangement of RMQC-3 of HDC, KoPT.**

Some changes in the Tender Document have been incorporated in Addendum (I). The complete Tender Document (including Tender Notice) and Addendum (I) are available in the websites [www.mstcecommerce.com](http://www.mstcecommerce.com) ; <http://eprocure.gov.in> ; <http://kolkataporttrust.gov.in> and <http://haldiadock.gov.in>

**KOLKATA PORT TRUST**  
**HALDIA DOCK COMPLEX**

**Tender No. SDM (P&E)/T/48/2019-20**

**E-Tender No. KoPT/Haldia Dock Complex/P&E Div/10/19-20/ET/38**

**ADDENDUM - I**

*CORRECTIONS / ADDITIONS / DELETIONS, ETC.*

**[Total Number of Pages : 1]**

**NOTE :**

1. This "Addendum-I" should be read in conjunction with Bidding Document (including Notice Inviting e-Tender).
2. Consequential changes, arising out of this Addendum-I, will be deemed to have been effected, even if the same were not incorporated specifically in the Bidding Document.
3. All other terms and conditions of the Bidding Document (including Notice Inviting e-Tender) will remain unchanged.

**Addendum -I**

**Tender No. SDM (P&E)/T/48/2019-20**

**E-Tender No. KoPT/Haldia Dock Complex/P&E Div/10/19-20/ET/38**

<b>Sl. No.</b>	<b>Page No.</b>	<b>Clause No.</b>	<b>As specified in the Bidding Document</b>	<b>To be deleted &amp; read as / Remarks</b>
<b>1.</b>	<b>6</b>	SOT 3.12	i) Starting date & time of submission of e-Tender at <a href="http://www.mstcecommerce.com/eprochome/kopt">http://www.mstcecommerce.com/eprochome/kopt</a> 29.07.2019 from 11:00 Hrs. (IST).	i) Starting date & time of submission of e-Tender at <a href="http://www.mstcecommerce.com/eprochome/kopt">http://www.mstcecommerce.com/eprochome/kopt</a> 31.07.2019 from 11:00 Hrs. (IST).
<b>2.</b>	<b>6</b>	SOT 3.12	ii) Closing date & time of submission of e-Tender at <a href="http://www.mstcecommerce.com/eprochome/kopt">http://www.mstcecommerce.com/eprochome/kopt</a> : 07.08.2019 up to 15:00 Hrs. (IST).	ii) Closing date & time of submission of e-Tender at <a href="http://www.mstcecommerce.com/eprochome/kopt">http://www.mstcecommerce.com/eprochome/kopt</a> : 14.08.2019 up to 15:00 Hrs. (IST).
<b>3.</b>	<b>6</b>	SOT 3.12	iii) Date & time of opening of Part-I (Techno-commercial Bid): 07.08.2019 up to 15:00 Hrs. (IST).	iii) Date & time of opening of Part-I (Techno-commercial Bid): 14.08.2019 up to 15:30 Hrs. (IST) onwards.

**HALDIA DOCK COMPLEX**

**KOLKATA PORT TRUST**

**QUERIES OF DIFFERENT FIRMS IN CONNECTION WITH THE PRE-BID MEETING HELD ON 24.07.2019**

**for**

**“Supply, Installation, Testing and Commissioning of 33 kV Over Head Line & Under Ground Cable from Intake Substation to GC Berth Substation for strengthening of power supply arrangement of RMQC-3 of HDC, KoPT.”.**

**Tender No. SDM (P&E)/T/48/2019-20**

**E-Tender No. KoPT/Haldia Dock Complex/P&E Div/10/19-20/ET/38**

<b>Sl. No.</b>	<b>Reference</b>	<b>Queries of the firms</b>	<b>HDC, KoPT's Clarifications</b>
1.	LIST OF APPROVED MAKES, page no. 95	<b>33 KV indoor type VCB:</b> Kindly confirm that whether the panel from the system house of respective approved manufacturer is acceptable to you or not	Panel from the system house is not acceptable
2.		<b>Control cable:</b> Kindly note that There is no separate BOQ item for Supply, Laying & termination of control cables for the Intake Sub-stn and G.C Berth Sub-stn end in your above tender document. Kindly provide the detailed scope of work for Control cables	Supply, Laying & Termination of Control Cables to be considered, against Installation, Testing & Commissioning of each item, wherever required as per Tender Condition.