

Kolkata Port Trust
HALDIA DOC COMPLEX

ADDENDUM/CORRIGENDUM NOTICE FOR:

NAME OF WORK: PROVIDING & LAYING D.I PIPE LINE AS WATER MAIN AND G.I/P.V.C RISING LINE FOR OVER HEAD TANK IN PLACE OF EXISTING OLD C.I WATER MAIN AND RISING LINE FROM CLUSTER 4, 5, 9 & 3RD OIL JETTY AT HALDIA TOWNSHIP, HDC, HALDIA.

E-TENDER No.: 2019_KoPT_525922

No. I&CF/SDM/RZ/19-20/ET/18/477

Dated: 23.12.2019

To

(All Bidders)

Reference tender document for the subject work, the following amendments shall be applicable:

ADDENDUM

Under Section –VI, Technical Specification, the following clause is hereby added as Clause 6.7. (x) –

<u>CLAUSES</u>	<u>DESCRIPTION</u>
----------------	--------------------

6.7 (x)	DI PIPES
---------	-----------------

Centrifugally Cast (Spun) Ductile iron pressure pipes with spigot & socket end, class K-9 conforming to IS:8329:2000 with latest amendments suitable for (push-on) rubber gasket jointing with centrifugally applied inside cement mortar lining with Portland Slag Cement as per IS: 455: 1989 with latest amendments and external Metallic Zinc Coating as per annex A of IS 8329 with finishing layer of Bitumen coating as per Annex. C of IS:8329. The standard length of the pipes are 5.5 and 6.00 meter.

DI SPECIALS

ISI marked Ductile Iron Fitting will be supplied as per IS: 9523/ 2000 with latest amendments of class K12 for push on joint/ Flanged Joint/ Mechanical joint with inside Cement Mortar lining and Outside zinc coating followed by black bitumen coating. Flange rating will be PN 10/ 16 for the same.

RUBER GUSKET

Ethylene Propylene Diene Monomer (EPDM) rubber gasket conforming to IS:5382 with latest amendments of Bulb-Type-2 as per IS:5382 with latest amendments; Heel Type-5, as per IS:5382 with latest amendments will have to be supplied.

CORRIGENDUM

Sl. No.	TENDER VOLUME/ PAGE NUMBER	REF.	EXISTING DETAILS	TO BE READ AS
1.	Item No. 10. Page No-49	Bill of Quantities (BOQ)	Provide, lay, fit and fix in proper alignment & gradient D.I. pipes [S.S] for underground work using high strength flexible nylon / rubber titon with approved lubricant as per specification. The rate shall include completed in all respect including Hydro testing.	Provide, lay, fit and fix in proper alignment & gradient D.I. pipes [S.S] [Class K-9] for underground work using high strength flexible nylon / rubber titon with approved lubricant as per specification. The rate shall include completed in all respect including Hydro testing. Ref. specification as per clause 6.7.(x).
2	Item No. 11. Page No-49	Bill of Quantities (BOQ)	Provide lower ,lay ,fit & fix Ductile Iron (D.I) flanged Pipe of required size conforming to I.S as required for successful completion of the work with necessary fixing materials like rubber gasket, bolts ,nut etc.to the newly laid water mains / bored Tube Well including cutting trench in any soil and back filling if required complete in all respect including Hydro Testing.	Provide lower ,lay ,fit & fix Ductile Iron (D.I) flanged Pipe of required size conforming to I.S as required for successful completion of the work with necessary fixing materials like rubber gasket, bolts ,nut etc.to the newly laid water mains / bored Tube Well including cutting trench in any soil and back filling if required complete in all respect including Hydro Testing. Ref. specification as per clause 6.7.(x).
3.	Item No. 12. Page No-50	Bill of Quantities (BOQ)	Provide lower ,lay ,fit & fix Ductile Iron (D.I) flanged Pipe fittings of required size conforming to I.S as required for successful completion of the work with necessary fixing materials like rubber gasket, bolts ,nut etc.to the newly laid water mains complete in all respect including Hydro Testing.	Provide lower ,lay ,fit & fix Ductile Iron (D.I) flanged Pipe fittings of required size conforming to I.S as required for successful completion of the work with necessary fixing materials like rubber gasket, bolts ,nut etc.to the newly laid water mains complete in all respect including Hydro Testing. Ref. specification as per clause 6.7.(x).

Sl. No.	TENDER VOLUME/ PAGE NUMBER	REF.	EXISTING DETAILS	TO BE READ AS
4.	Item No. 13. Page No-50	Bill of Quantities (BOQ)	Provide lower, lay, fit & fix Ductile Iron (D.I) Spigot & Socketed Pipe fittings of required size conforming to I.S as required for successful completion of the work with necessary fixing materials like rubber gasket, bolts, nut etc.to the newly laid water mains complete in all respect including Hydro Testing.	Provide lower, lay, fit & fix Ductile Iron (D.I) Spigot & Socketed Pipe fittings of required size conforming to I.S as required for successful completion of the work with necessary fixing materials like rubber gasket, bolts, nut etc.to the newly laid water mains complete in all respect including Hydro Testing. Ref. specification as per clause 6.7.(x).
5.	Item No. 14. Page No-50	Bill of Quantities (BOQ)	Provide lower, lay, fit & fix Ductile Iron (D.I) Spigot or Socketed Tail Piece of required size conforming to I.S as required for successful completion of the work with necessary fixing materials like rubber gasket, bolts, nut etc.to the newly laid water mains complete in all respect including Hydro Testing.	Provide lower, lay, fit & fix Ductile Iron (D.I) Spigot or Socketed Tail Piece of required size conforming to I.S as required for successful completion of the work with necessary fixing materials like rubber gasket, bolts, nut etc.to the newly laid water mains complete in all respect including Hydro Testing. Ref. specification as per clause 6.7.(x).

Bidders are requested to submit scan copy of this ‘Corrigendum’ dully signed under office seal along with their offer as an acknowledgement and acceptance.

Sd/-
B.Sengupta
 Sr. Dy. Manager, RZ & Spl RT
 I & CF Division
 Haldia Dock Complex