

Annexure-III

**3rd ADDENDUM AND CORRIGENDUM**


**Name of the Tender : BANK PROTECTION WORK INFRONT OF PROPOSED BULK/LIQUID CARGO HANDLING TERMINALS AT SHALUKKHALI, HALDIA, HDC (PHASE-I).**

**Tender No. : I&CF/IZ&R/T/336**

The following amendments to be applicable:

Sl. No.	Reference	To be read as	In place of
1.	Table B Sl. No.1 Clause 4(ii) of Particular Specifications of work, Page-23 of Tender Document	Property - Apparent Opening Size Test Method – ASTM D 4751 <b>Maximum</b> Average Roll Value (MARV) – <b>100 micron</b>	Property - Apparent Opening Size Test Method – ASTM D 4751 Minimum Average Roll Value (MARV) – 100 micron.
2.	Item No. 4(c) of BOQ, Page-39 of Tender Document	(c) Apparent opening size (A.O.S) 100 micron ( <b>Maximum</b> ) and water flow (h=100mm) 25Ltr./Sq.M/S (Min).	(c) Apparent opening size (A.O.S) 100 micron and water flow (h=100mm) 25Ltr./Sq.M/S (Min).

N.B. : (i) The other Terms and Conditions of the tender shall remain unaltered.  
(ii) Bidders are requested to submit this "3<sup>rd</sup> Addendum and Corrigendum" duly signed under office seal along with their Techno-Commercial i.e. Cover-I offer as an acknowledgement and acceptance.

  
**Sr. Dy. Manager (IZ&R)**  
**I&CF Division**  
**Haldia Dock Complex**

Annexure-IV

Reply to the Pre-bid Query


Name of the Tender : BANK PROTECTION WORK INFRONT OF PROPOSED BULK/LIQUID CARGO HANDLING TERMINALS AT SHALUKKHALI, HALDIA, HDC (PHASE-I).

Tender No. : I&CF/IZ&R/T/336

Date of Pre-bid meeting: 21.06.2021

Time: 11:00 A. M.

Sl No.	Bidder's Query	Response to the said Query
1	To include/introduce JOINT VENTURE (J. V.) provision in the overall interest of tender.	The request for inclusion of the provision of the JOINT VENTURE (J. V.) in the eligibility criteria cannot be acceded to.

  
Sr. Dy. Manager (IZ&R)  
I&CF Division  
Haldia Dock Complex