

SYAMA PRASAD MOOKERJEE PORT, KOLKATA
HALDIA DOCK COMPLEX

Tender No. SDM(P&E)/T/13/2021-2022

ADDENDUM - II

CORRECTIONS / ADDITIONS / DELETIONS, ETC.

[Total Number of Pages : 2]

NOTE :

1. This "Addendum-II" should be read in conjunction with Bidding Document (including Notice Inviting e-Tender).
2. Consequential changes, arising out of this Addendum-II, will be deemed to have been effected, even if the same were not incorporated specifically in the Bidding Document.
3. All other terms and conditions of the Bidding Document (including Notice Inviting e-Tender) will remain unchanged.

Addendum -II

Tender No. SDM(P&E)/T/13/2021-2022

Sl. No.	Page No.	Clause No.	As specified in the Bidding Document	To be deleted & read as / Remarks
1.	6	3.6	Completion Period:75 days	Completion Period:100 days
2.	92	1.18 under SECTION - VIII SPECIAL CONDITIONS OF CONTRACT (SCC)	The supply, installation and commissioning of the system to be completed in all respect within 75 (seventy five) days from the date of receipt of order.	The supply, installation and commissioning of the system to be completed in all respect within 100 (hundred) days from the date of receipt of order.
3.	96	6.0 under SECTION - VIII SPECIAL CONDITIONS OF CONTRACT (SCC)	All the jobs (including submission of As Built Drawings), as per contract, are to be completed within 75 (seventy five) days from the date of issue of Letter of Acceptance (LOA) [i.e. award of contract].	All the jobs (including submission of As Built Drawings), as per contract, are to be completed within 100 (hundred) days from the date of issue of Letter of Acceptance (LOA) [i.e. award of contract].
4.	6	SOT 3.11	ii) Closing Date & time of submission of e-tender 22.02.2022 up to 15:00 Hrs. (IST) onwards.	ii) Closing Date & time of submission of e-tender 01.03.2022 up to 15:00 Hrs. (IST) onwards.
5.	7	SOT 3.11	iii) Date & time of opening of (Techno-commercial Bid & Price Bid) 22.02.2022 up to 15:30 Hrs. (IST) onwards.	iii) Date & time of opening of (Techno-commercial Bid & Price Bid) 01.03.2022 up to 15:30 Hrs. (IST) onwards.

SYAMA PRASAD MOOKERJEE PORT, KOLKATA
HALDIA DOCK COMPLEX

QUERIES OF DIFFERENT FIRMS IN CONNECTION WITH THE PRE-BID MEETING HELD
ON 25.01.2022 AND CLARIFICATIONS THEREOF.

Tender No. : SDM(P&E)/T/13/2021-2022

Sl. No.	Reference	Queries of the firms	HDC, SMP Kolkata Clarifications
1.	Nil	The LMO vessel, AV coil, other accessories are on hiring basis or outright sale. The one time installation component quotation will be different depending on whether it is outright sale or hiring basis.	As per tender stipulations, installation of LMO vessel, AV coil and other accessories are for outright sale and not on hiring basis.
2.	Nil	Regular LMO refilling- The bidder winning the tender will be responsible for LMO refilling for 1 year or 5 years. If the bidder will be responsible for LMO refilling for 5 years period, there should be provision of escalation.	Pl see Clause No.IV under Section-VI at Page no.29. The contractor, as per the rate quoted by them shall supply LMO as per the requirement of Port Hospital. The contractor shall quote the rate for supply of oxygen F.O.R at the proposed storage yard at Port hospital with price revision of 5% per year. The contract period for supply of LMO in the present contract is for five years.
3.	Nil	The LMO facility requires PESO license which takes around 2-3 months. Therefore the completion period of the project should be 120 days.	Pl. see Sl.No.1&2 of Addendum-II