

**Syama Prasad Mookerjee Port , Kolkata
HALDIA DOCK COMPLEX**

ADDENDUM / CORRIGENDUM NOTICE FOR:

NAME OF WORK: Construction of 05 (Five) nos. General Managers' Bungalows including development & landscaping of adjoining areas at HDC Township, Haldia.

TENDER NO.: I&CF/SDM/RZ/ET/39

No. I&CF/SDM/RZ/ET/39/75/1

Dated: 12.05.2022

**To
(All Bidders)**

Reference tender document for the subject work, the following amendments shall be applicable:

Sl. No.	TENDER VOLUME / PAGE NUMBER	REFERENCE	EXISTING DETAILS	TO BE READ / REPLACED AS
1	Bill of Quantities	Section-B: Land Scaping & Boundary Wall	CuM	RM
2.	-Do -	Item No. 4 Section-A: Civil Work Item No. 33 under Description of Item	Supplying, fitting & fixing factory made Pre-laminated Colour solid panel foam PVC (density shall not be less than 600 kg/cum) door shutter consisting of 19 SWG thick M.S. tube of size 40mm X 20mm for styles and top, lock & bottom rail and welded together to form outer framework including a coat of approved make steel primer. M.S. frame shall be covered with 5mm thick heat moulded PVC channel to form 30mm X 100mm styles and 5mm	Supplying, fitting & fixing factory made pre-laminated Colour solid panel foam PVC (density shall not be less than 600 kg/cum) door shutter consisting of 19 SWG thick M.S. tube of size 40mm X 20mm for styles and top, lock & bottom rail and welded together to form outer framework including a coat of approved make steel primer. M.S. frame shall be covered with 5mm thick heat moulded PVC channel to form 30mm X 100mm styles and 5mm thick PVC sheet on either side of panel to form

3.	-Do-	Section-A: Civil Work Item No. 33 under Unit	thick PVC sheet on either side of panel to form 30mm X 125mm top, lock & bottom rail where 15mm (5mm X 3) thick and 20mm wide PVC sheet to be provide as gap insert for top & bottom rail. For panel 10mm PVC sheet to be fitted with stiles & rails with 30mm X 5mm PVC sheet beading on either side of panel and additional 30mm PVC beading as gap insert below top & bottom rail on either side of panel joined together using solvent cement adhesive.	30mm X 125mm top, lock & bottom rail where 15mm (5mm X 3) thick and 20mm wide PVC sheet to be provide as gap insert for top & bottom rail. For panel 10mm PVC sheet to be fitted with stiles & rails with 30mm X 5mm PVC sheet beading on either side of panel and additional 30mm PVC beading as gap insert below top & bottom rail on either side of panel joined together using solvent cement adhesive along with supplying and fixing of factory made door frame made of single piece extruded solid PVC profile with homogenous fine cellular structure of size 62mm X 32mm as approved, to suit the above shutter and shall be fixed to wall as per direction. SqM
----	------	---	---	--

Bidders are requested to upload this 'Addendum & Corrigendum' dully signed under office seal along with their Techno-Commercial i.e. Cover-I offer as an acknowledgement and acceptance.

Sr. Dy. Manager (Spl. RT & RZ)
I&CF Division
Haldia Dock Complex